



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 06/07/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT-2	MALE PLUG PROBLEM	CHANGED	00:30:00	00:45:00	
2	OHP	RSC0-9A	TRIPPED ON OLR	RESET DONE	03:30:00	03:45:00	
3	OHP	CO-35	OLR ACTED	RESET DONE	23:40:00	23:45:00	
4	OHP	TBS ON CO-20	LT NOT WORKING	RECLAMER HEIGHT LIMIT TIED THEN TESTED	00:45:00	01:00:00	
5	OHP	TBS on CO20	Luff not working	bcz of Dummy break full tight , made loose by mechanical . then okay	22:00:00	22:20:00	
6	CHP	CC 131	Tripped on overload	reset done	04:30:00 05:15:00	04:35:00 05:20:00	
7	CHP	CC 113A	Tripped on overload	reset done	05:27:00	05:35:00	
8	CHP	CC 111 , S-3	LT not working due to drive tripped on overload	Drive reset	23:30:00	23:40:00	
9	CHP	CC 32, SCR 5	LT not working	MPCB 3 TRIPPED , made on	01:15:00	01:30:00	
10	CHP	CC 223	Not healthy due to chute sensor acted	Found chute jamming is there, informed to operation	02:10:00	02:30:00	
11	CHP	CC 40 , SCR 6	BC not working	BC chute sensor bypassed due to rain	05:32:00	05:45:00	Informed to A shift
12	CHP	CC 44	Tripped on overload	reset done	01:45:00	01:50:00	
13	CHP	CC 42	ZSS acted due to probe loose condition	Probe fixed properly	02:40:00	03:00:00	
14	WT	CP-3	NOT MOVING	D3 OLR ACTED ... OLR contact PROBLEM .. ADJUSTED THEN OK	00:30:00	01:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/07/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	WT	OC-1A	OLR ACTED DUE TO JAMMING	RESET DONE	04:50:00 05:05:00 05:15:00	05:00:00 05:10:00 05:20:00	
16	WT	OC 1A	Failed to start due to pull chord acted	reset done	22:35:00	22:45:00	
17	IOSA	TBS	LT limit acted	released	23:15:00	23:35:00	