



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/08/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR acted	reset done	06:20:00	06:30:00	
2	OHP	BRC on CO 31	LT not taking place due to M6 tripped	reset done	08:50:00	09:00:00	
3	OHP	BRC on CO 28	BC not running due to OLR acted	reset done	08:45:00	08:55:00	
4	OHP	CO 85	OLR acted	reset done	11:15:00	11:26:00	
5	OHP	WOBR on CO 25	Luff not working due to oil level low	Inform to operation	12:30:00	12:50:00	
6	CHP	CC 37 , S 1	LT not working	Drive tripped , reset	10:11:00	10:30:00	
7	CHP	CC 32 , SCR 5	LT not working	Local emergency acted , released	11:45:00	12:00:00	
8	CHP	CC 104, SCR 9	BW not running due to oil temp high	checked, found that oil cooler motor tripped . Made on , then ok	13:20:00	13:40:00	
9	CHP	CC 114	Tripped on overload (3 times)	reset done	10:00:00	13:25:00	
10	CHP	VF 101	tripped on overload	reset done	12:00:00	12:10:00	
11	CHP	CC 54	Tripped on overload (5 times)	reset done	08:30:00	13:00:00	
12	CHP	CC 51	MPD Tripped (many times)	reset	08:30:00	13:25:00	
13	WT	OT 4	Hydraulic pump not starting	Control mcb tripped in plc panel , made on	06:45:00	07:00:00	