



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/09/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-28	B/C OLR ACTED	RESET DONE	08:50:00	09:00:00	
2	OHP	TBS ON CO-22	C/S ACTED DUE TO MATERIAL JAMMING	AFTER CLEAR THE MATERIAL THAN C/S OK	09:50:00	10:00:00	
3	OHP	CO-2A TO RSCO-10A	CHUTE VIBRATOR NOT WORKING	CHECKED AND FOUND CHUTE VIBRATOR FELL DOWN	09:00:00	09:30:00	INFORM TO G-SHIFT
4	OHP	CO-84	OLR ACTED	RESET DONE	12:20:00	12:30:00	
5	OHP	RSCO-1A (C/D)	NOT MOVE CHECKED FOUND POWER MCCB TRIP	MADE ON THAN OK	13:40:00	13:50:00	
6	CHP	CC-21(C/D)	OLR ACTED	RESET DONE	06:40:00	06:50:00	
7	CHP	CC-54	OLR ACTED	OLR RESET DONE	12:20:00	12:30:00	
8	CHP	CC-131	OLR ACTED	RESET DONE	09:05:00	09:10:00	
9	CHP	CC-33 R-1	REPORTED B/C STOPPING FREQUENTLY CHECKED AND FOUND YARD INTERLOCK ZS CAGE STUCK UP WITH COAL	COAL REMOVED THAN OK	07:00:00	07:20:00	
10	CHP	CC-39 S-1	LT NOT TAKING PLACE CHECKED POTENTIAL METER ZERO	NOW INCREASED THAN OK	07:20:00	07:30:00	
11	CHP	CC-125	OLR ACTED	RESET DONE	11:00:00	11:15:00	
12	CHP	CC-44	OLR ACTED	RESET DONE	10:00:00	10:10:00	
13	CHP	CC-51	OLR ACTED DUE TO FEEDING CONVEYOR STOP	RESET DONE	13:15:00	13:20:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/09/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC-40 SCR-3	REPORTED B/C STOPPING FREQUENTLY	CHECKED AND FOUND NO ELECTRICAL PROBLEM	08:35:00	09:00:00	