



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/06/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR ACTED (2TIMES)	RESET	23:00:00	23:15:00	
2	OHP	WOBR ON CO 26	DOWN LIMIT ACTED	RELEASED	23:30:00	23:45:00	
3	OHP	CO 15	TRIPPED	RESET DONE THAN OK	23:40:00	00:00:00	
4	OHP	LC 7	ALL CONVEYORS RED OM 13 I/C TRPPED	OM 13 I/C CHARGED	00:15:00	01:00:00	
5	OHP	TT1 TT2 TT3	POSITION INDICATIONS PROBLEM	C/S RESET THAN OK	01:00:00	01:30:00	
6	OHP	CO 25	OLR ACTED	RESET	03:15:00	03:30:00	
7	OHP	BRC ON CO 31	B/C OLR ACTED(2TIMES)	RESET	04:00:00	04:15:00	
8	CHP	CC 54	OLR ACTED (3TIMES)	RESET	04:00:00	05:15:00	
9	CHP	CC 39 SCR 7	B/C NOT RUNNING C/S ACTED	SENSOR CLEANING THAN OK	00:50:00	01:15:00	
10	CHP	CC 104 SCR 9	B/C NOT RUNNING	WRONG COMPLAINT	02:50:00	03:05:00	
11	CHP	CC 125	OLR ACTED	RESET	05:15:00	05:20:00	
12	WT	OP 3	OVER TRAVELED MIDDLE PAD FALL DOWN	C CLAMP ADJUSTED	02:00:00	02:10:00	