



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/05/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------|---|---------------------------------|----------|----------|-------------------------|
| 1 | OHP | TBS ON CO21 | RIGHT LUFF NOT TAKING PLACE OLR ACTED | RESET | 06:30:00 | 06:45:00 | BRAKE ADJUSTED |
| 2 | OHP | CO 29 | OLR ACTED | RESET | 08:45:00 | 08:55:00 | |
| 3 | OHP | CO 35 | OLR ACTED | RESET | 09:00:00 | 09:15:00 | |
| 4 | OHP | CO 34 | OLR ACTED | RESET | 10:30:00 | 10:40:00 | |
| 5 | OHP | BRC ON CO33M | B/W 2 OLR ACTED | RESET DONE | 10:40:00 | 11:00:00 | |
| 6 | OHP | TT2 ON CO19 | POSITION INDICATION PROBLEM CABLE GOT CUT | JOINT DONE THAN OK | 10:40:00 | 11:00:00 | |
| 7 | CHP | CC131 | OLR ACTED (2 times) | RESET | 07:10:00 | 07:30:00 | DUE TO MATERIAL JAMMING |
| 8 | CHP | CC 32 | OLR TRIPPED | RESET | 07:55:00 | 08:00:00 | |
| 9 | CHP | SCR 9 ON CC104 | B/C NOT RUNNING | FAULT RESET DONE THAN OK | 09:50:00 | 10:00:00 | |
| 10 | CHP | SCR 8 ON CC 112 | LUFFING DOWN LIMIT ACTED | BY PASSED OPERATION REQUIREMENT | 11:50:00 | 11:55:00 | |