



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/12/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO-25	REPORTED SLEW NOT WORKING OLR ACTED	RESET DONE THAN OK	07:25:00	07:35:00	
2	OHP	WOBR ON CO-29	REPORTED ALL DRIVES ARE NOT WORKING FOUND LOWER LIMIT ACTED	RELEASED THAN OK	09:10:00	09:25:00	
3	OHP	WOBR ON CO-25	REPORTED B/C NOT RUNNING CHECKED AND FOUND ZSS CAGE STUCK UP WITH STONE	REMOVED THAN OK	10:00:00	10:10:00	
4	OHP	WOBR ON CO-29	REPORTED LT NOT TAKING PLACE FOUND DRIVE AND M-3 TRIP (2TIMES) DUE TRACK JAMMING	RESET DONE AND INFORMED TO OPERATION	10:10:00 10:35:00	10:25:00 10:45:00	
5	OHP	TBS ON CO-7A	REPORTED LT NOT TAKING PLACE FOUND INTERLOCK LUFF LIMIT PROBLEM	LIMIT PROPERLY TIE THAN OK	09:20:00	09:35:00	
6	CHP	CC-13	REPORTED NOT RUNNING CHECKED AND FOUND POWER MCCB OUT GOING JUMPERS MELTED	REPLACED WITH CC-12 MADLU	09:45:00	10:15:00	
7	CHP	CC-19	REPORTED NOT HEALTHY OLR ACTED DUE TO MATERIAL JAMMING	RESET DONE AND INFORMED TO OPERATION	09:33:00	09:40:00	
8	CHP	CC-117	OLR ACTED	RESET DONE	09:50:00	10:00:00	
9	CHP	CC-51	MPD TRIPPED (FEEDING CONVEYOR STOPPED) (20 TIMES)	RESET DONE	09:20:00	13:10:00	
10	CHP	CC-131	TRIPPED ON OLR (4TIMES)	RESET DONE	09:00:00	12:20:00	
11	WT	OT-2	DRIVE -2 TRIP PGF-1 FAULT (2TIMES)	RESET DONE	12:30:00	12:35:00	