



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 05/01/2026

Area: WT

Equipment	Job
OP 7	Trolley line inspection done and noted defects
OP 5	Panel and Motor side ppm done
OP 5	Anti collision sensor circuit checked found sensor not functioning
OP1,3,4 and 5	After rake maintenance done
OP 4	D1 and 2 cascade panel " AR" relay replaced
OC1A level	120w LEDs installed 2 nos, near crane approach point