



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/09/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

| Sl No | Area | Equipment       | Problem                              | Action             | From     | To       | Remarks |
|-------|------|-----------------|--------------------------------------|--------------------|----------|----------|---------|
| 1     | OHP  | CO 9            | not healthy,OLr acted,DMPR trips     | reset              | 07:00:00 | 07:10:00 |         |
| 2     | OHP  | RSCO 6A(c)      | olr acted,track jamming              | reset              | 08:00:00 | 08:15:00 |         |
| 3     | OHP  | CO 48           | OLR acted                            | reset              | 08:20:00 | 08:25:00 |         |
| 4     | CHP  | CC 51           | MPD trips,stop feeding conveyor      | reset              | 07:00:00 | 07:05:00 | 4 times |
| 5     | CHP  | CC 29 TT on 31  | bit missing ,cable loose in I/O rack | tightened          | 11:30:00 | 11:35:00 |         |
| 6     | CHP  | CC 201 ,202,203 | OLR acted                            | reset              | 08:00:00 | 08:10:00 |         |
| 7     | CHP  | CC 49           | not healthy,BRS acted                | reset              | 12:35:00 | 12:48:00 |         |
| 8     | CHP  | CC 104 SCR9     | cjd acted                            | wrong complaint    | 10:40:00 | 10:45:00 |         |
| 9     | WT   | OT4             | D 1 tripped in PGF1 fault            | reset              | 07:40:00 | 07:45:00 |         |
| 10    | WT   | CP 1            | no movement,no power,ACB tripped     | ACB made on,pad ok | 13:00:00 | 13:10:00 |         |