



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 29/08/2025

Shift: C

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO -32	LT NOT TAKING PLACE CHECKED AND FOUND	M-1 OLR ACTED RESET DONE	22:30:00	22:50:00	
2	OHP	TBS ON CO-23	LT NOT TAKING PLACE	CHECKED AND FOUND BRAKES NOT RELEASING EVEN THOUGH MAGNETIZING.	22:50:00	23:10:00	INFORMED TO MECHANICAL. ADJUSTMENT DONE AND TESTED OKAY
3	OHP	TBS ON CO-20	REPORTED LT NOT TAKING PLACE	CHECKED AND FOUND MAIN CONTROL IN OFF CONDITION. MAIN CONTROL MADE ON AND TESTED OKAY	00:10:00	00:30:00	NO ELECTRICAL DELAY. OPERATOR DIDNT MAKE ON CONTROL.
4	OHP	CO-29	REPORTED TRIPPED	OLR ACTED.RESET DONE	02:30:00	02:40:00	
5	OHP	CO-26	REPORTED TRIPPED	OLR ACTED.REST DONE	05:20:00	05:30:00	
6	OHP	TW-6(CO-18 TO CO-23)	REPORTED NOT MOVING	OLR ACTED.RESET DONE	02:00:00	02:10:00	
7	OHP	BRC ON CO-31	REPORTED INTERLOCK PROBLEM	PROBE REPLACED AND ZSS INTERLOCK PROBE NOT CONNECTED AT CJB FOR THE CORRESPONDING FEEDING CONVEYOR.CONNECTED AND TESTED OKAY	01:15:00	02:00:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 29/08/2025

Shift: C

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
8	CHP	CC-51	REPORTED TRIPPED.	OLR ACTED.RESET DONE(2TIMES)	01:10:00 05:30:00	01:15:00 05:35:00	
9	CHP	CC-114	REPORTED TRIPPED	OLR ACTED.RESET DONE(2TIMES)	01:15:00 03:54:00	01:25:00 04:00:00	
10	CHP	CC-51A	REPORTED TRIPPED	OLR ACTED.RESET DONE	01:40:00	01:45:00	
11	CHP	CC-31 SCR-4	REPORTED ALL DRIVES NOT WORKING	CHECKED AND FOUND CONTROL IN OFF CONDITION.CONTROL MADE ON AND TESTED OKAY.LT ALSO NOT TAKING PLACE.FOUND TRACK JAMMING	22:40:00	23:00:00	INFORMED TO OPERATION TO CLEAR JAMMING
12	CHP	CC-40 SCR-3	REPORTED SLEW NOT TAKING PLACE	SLEW LIMIT ACTED AND JAMMING FOUND.LIMIT RELEASED AND INFORMED TO OPERATION TO CLEAR JAMMING	00:10:00	00:20:00	
13	CHP	CC-114 SCR-9	REPORTED B/C NOT RUNNING	MOTOR OLR ACTED.RESET DONE AND TESTED OKAY	02:50:00	03:00:00	
14	CHP	CC-41	CJD NOT WORKING	CHECKED AND FOUND CJD MODULE PROBLEM.MODULE REPLACED AND TESTED OKAY	03:10:00	03:30:00	
15	CHP	CC-108	REPORTED TRIPPED	OLR ACTED.RESET DONE	04:25:00	04:30:00	
16	WT	OP-1	REPORTED NOT MOVING	DRIVE-6 OLR ACTED.RESET DONE	03:00:00	03:20:00	