



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/09/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO-29	B/C STOPPING ON ZSS CHECKED ZSS PROBE DAMAGED	ZSS PROBE REPLACED THAN OK	07:00:00	07:20:00	
2	OHP	CO-25	REPORTED STOPPING ON ZSS CHECKED ZSS PROBE DAMAGED	ZSS PROBE REPLACED WITH NEW PROBE THAN OK	09:00:00	09:15:00	
3	OHP	BF-2A	FREQUENTLY STOPPED CHECKED AND FOUND ZSS PROBE LOOSE	ZSS PROBE PROPERLY FIXED THAN OK	07:40:00	07:50:00	
4	OHP	BRC ON CO 34	LT NOT TAKING PLACE CHECKED PCRD O/T ACTED	RELEASED THAN LT OK	10:00:00	10:20:00	
5	CHP	CC-131	OLR ACTED	RESET DONE	07:40:00	07:50:00	
6	CHP	CC-51	OLR ACTED DUE TO FEEDING CONVEYOR STOP	RESET DONE	09:50:00	10:00:00	
7	CHP	CC-29	OLR ACTED	RESET DONE	06:15:00	06:22:00	
8	CHP	CC-22 (B/D)	OLR ACTED	RESET DONE	07:00:00	07:10:00	
9	CHP	CC-22	C/S NOT HEALTHY	C/S CLEANED THAN OK	07:15:00	07:25:00	
10	CHP	CC-104 AND CC-105	NOT RUNNING BRS SUPPLY TRIPED IN CM-16 I/O RACK MCB	MCB MADE ON	06:00:00	07:00:00	
11	CHP	CC-37 SCR-7	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED THAN OK	08:20:00	08:30:00	
12	CHP	CC-37 SCR-7	B/C NOT RUNNING CHECKED C/S ACTED DUE TO WET COAL	AFTER MATERIAL CLEANED THAN OK	08:50:00	09:20:00	
13	CHP	CC-104 SCR-9	SLEW NOT WORKING MPR TRIP	RESET DONE THAN OK	10:50:00	11:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/09/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC-125 CC-44	OLR ACTED	RESET DONE	11:05:00	11:10:00	
15	CHP	CC-40 SCR-3	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED THAN OK	11:10:00	11:20:00	
16	CHP	CC-37 SCR-7	LT NOT TAKING PLACE DRIVE TRIP DUE TO TRACK JAMMING	RESET DONE	12:15:00	12:20:00	
17	WT	OP-9	REPORTED NOT MOVE F/R CHECKED AND FOUND ACB TRIP IN LC-10B	ACB MADE ON THAN OK	10:20:00	10:30:00	
18	WT	CO-4 (B/D)	MPCB TRIP	RESET DONE	10:40:00	10:50:00	