



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/05/2025

Shift: C

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tbs on co 19	lbc luffing not taking place/olr acting frequently due to brake gap dristub.	informed to mechanical	00:15:00	01:05:00	no delay
2	OHP	brc on co 28	bc not running/olr acted due heavy material on the belt	phase sequence changed for operation request and again normalised	23:35:00	00:10:00	
3	OHP	brc on co 33m	oil temp .high/sensor cleaning done	fault reset done then ok	22:30:00	23:00:00	
4	OHP	brc on co 32	bc not running/olr acted	reset done	02:30:00	03:00:00	
5	CHP	scr 2 on cc35	lt not taking place pcrd tension limit acted	released .	03:05:00 23:30:00	03:15:00 23:40:00	
6	CHP	scr 7 oncc 39	be & slew; not working/	fault reset done	00:00:00	00:10:00	
7	CHP	cc 40	stopping frequently /EPB bit missing due belt piece toughing to the pb	belt removed then ok	01:50:00	02:15:00	
8	WT	op 7	F/reverse not taking place/ reverse limit acted	reset done	01:05:00	01:15:00	due bush/to be cut