



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/06/2025

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	scr 7 on cc39	slew not taking place/brake fail fault acted in spider of drive 2	reset done	16:45:00	17:00:00	
2	CHP	scr 5 on cc32	slew not taking place/slewing done from ohp side to gvm side bc stopped	wrong operation done.restarted then ok	15:30:00	15:45:00	
3	CHP	cc 201,202,203	olr acted	reset done	14:20:00	14:30:00	
4	CHP	scr 4 on cc33	slew not taking place/right limit acted	reset done	15:00:00	15:10:00	
5	CHP	cc 32	tripped on olr	reset done	18:10:00	18:20:00	
6	CHP	scr 9 on cc104	bc not running/bc position not getting towards gvm side	high given to fuse then getting signal	18:25:00	18:35:00	
7	CHP	cc 117	tripped olr	reset done	16:35:00	16:50:00	
8	WT	op 1	f/reverse not taking place	acb tripped/made on tested ok	15:40:00	15:50:00	
9	WT	ot 4	e stop acted/	bypssed at i/o rack	21:35:00	21:50:00	
10	WT	ot 4	hydraulic pump not running/oil temp. high	inform to mech.	20:30:00	20:40:00	