



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/07/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 111(B)	olr acted	reset	01:00:00	01:05:00	
2	OHP	CO 29	OLR acted	reset	03:25:00	03:30:00	
3	OHP	TBS on CO 7A	LT not taking place,drive trips in overload	reset	23:12:00	23:25:00	
4	OHP	CO 35A	OLR acted	reset	04:00:00	04:10:00	
5	OHP	CO 26	OLR acted	reset	04:30:00	04:40:00	
6	OHP	BRC 3 on CO 8A	LT not taking place,drive trips,than PCRD panel control mcb problem	drive reset,PCRD panel MCB replaced	00:30:00	01:20:00	
7	OHP	TT 4 on CO 20	chute position bit was missing,fuse Tb cable was loosened	cable tightened	01:30:00	01:40:00	
8	CHP	CC 32 SCR 5	LT not working,OT acted	OT released	00:08:00	00:15:00	
9	CHP	CC 39 S1	slew not working,jamming	informed operation	00:16:00	00:30:00	
10	CHP	CC 32 SCR 5	BC healthy stop,in ZSS coal stucked	coal removed	01:40:00	01:55:00	
11	CHP	CC 45	OLR acted	reset	05:25:00	05:30:00	
12	CHP	CC 112 scr 8	slew not working,checked slew limit acted	reset	04:30:00	04:50:00	
13	CHP	CC 33 SCR 4	luffing not working,	wrong complaint	05:08:00	05:15:00	
14	CHP	CC 44	OLR acted, material full	reset	05:15:00	05:20:00	