



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 05/02/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 56 ZSS ACTING	CAGE STUCK	MADE IT FREE	02:20:00	02:30:00	
2	OHP	WBR ON CO 25	PCRD O/T ACTED	RELEASED	22:45:00	23:00:00	
3	OHP	BRC ON CO 28 B/W1	ZSS ACTING DUE TO NEUTRAL LOOSE IN CJB 2	TIGHTENED THEN OK	01:40:00	01:55:00	
4	OHP	WBR ON CO 25 LT	M2 TRIPPED DUE TO TRACK JAMMING	MADE IT ON	03:00:00	03:15:00	
5	CHP	cc 51	FEEDING CONV OLR ACTED	RESET	03:50:00	05:40:00	3 TIMES
6	CHP	CC 58	OLR ACTED	RESET	00:00:00	01:00:00	5 TIMES
7	CHP	CC 130 TIS	MPCB TRIPPED	MADE IT ON	05:00:00	05:15:00	
8	CHP	RG2 F/G	OLR ACTED	RESET	05:00:00	05:10:00	
9	CHP	CC 53 RED	P/C ACTED	RELEASED	00:40:00	00:55:00	
10	CHP	CC 28	OLR ACTED	RESET	02:00:00	02:05:00	
11	CHP	CC 29 ON CC 33	POSITION SENSOR PROBLEM	BYPASSED	05:30:00	05:45:00	
12	WT	OP1	REV CONTACTOR COIL BURNT	REPLACED	23:50:00	00:30:00	