



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/01/2026

Incharge(s): Lal Singh,Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc om co-32	ZSS CAGE STUCK	MADE FREE	15:00:00	15:15:00	
2	OHP	CO-13 BD	TRIPPED ON OLR	RESET DONE	15:40:00 17:40:00	15:50:00 17:45:00	
3	OHP	CO12 BD	TRIPPED ON OLR	RESET DONE	17:00:00	17:15:00	
4	OHP	TBS ON CO 20	LBC TRIPPED ON OLR	RESET DONE	18:00:00	18:10:00	
5	OHP	BRC ON CO -31	CT NOT WORKING ... CHAIN PROBLEM	INFORMED MECH	20:27:00	20:40:00	
6	OHP	CO-5, 6, 7	NOT HEALTHY .... LC-13 TRIPPED SO NO SUPPLY IN IO RACK	ACB CHANGED	18:45:00	19:55:00	
7	CHP	CC-105	BRS ACTED ...	SENSORS CLEANED AND RESET DONE	17:50:00	18:10:00	
8	CHP	CC108	TRIPPED ON OLR	RESET DONE	19:15:00 21:00:00	19:20:00 21:05:00	
9	CHP	CC-58	TRIPPED	RESET DONE	18:00:00	18:20:00	
10	CHP	CC-54	TRIPPED 3 TIMES	RESET DONE	20:20:00	21:00:00	
11	CHP	CC-131	TRIPPED	RESET DONE	21:46:00	21:50:00	
12	CHP	CC-51	MPD TRIPPED	RESET DONE	21:05:00	21:10:00	
13	IOSA	LBDS -2	BUS COUPLER PROBLEM	INCOMER MADE ON	14:00:00	16:00:00	