



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 22/10/2025

Area: WT

Equipment	Job
OP 2	Emergency Switch replaced (not making properly)
OP 3	Trolley line inspection done ,col no 71 to 72 bus bar middle and bottom adjusted
OP 2	D4 motor removed and shifted to tippler house,bypassed it (5 motors in circuit)
OP 2	Motor side ppm done, found D4 motor ,stator winding burnt
OP 2,3 and 8	after rake maintenance done