



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/07/2025

Shift: A

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 34	LT SELECTOR SWITCH ON CD MISSING	KNOB PROVIDED	07:50:00	08:10:00	
2	OHP	CO-76R	TRIPPED ON OLR	RESET DONE	10:45:00	11:00:00	
3	OHP	CO-22 TBS	CHUT VIBRATOR Y PHASE BURNT IN TB	RECONNECTED	10:40:00	11:00:00	
4	CHP	CC-114	TRIPPED ON OLR	RESET DONE	08:15:00	08:25:00	
5	CHP	CC-53	TRIPPED ON OLR	RESET DONE	08:40:00	08:45:00	
6	CHP	CC 54	Tripped on overload	reset done	09:15:00	09:20:00	
7	CHP	CC 38 , SCR 3	BC stopping frequently	Belt off centering , informed to mechanical	09:50:00	10:20:00	
8	CHP	CC 26A	ZSS acted due to coal stucked in cage	cleaned and given clearance	07:15:00	07:30:00	
9	CHP	CC 27A TT	Position signal on CC 39 missing	position sensor adjusted , then okay	11:15:00	11:30:00	
10	WT	OP 2	D-1 tripped	made on	07:15:00	07:25:00	
11	WT	OP 1	D-5 tripped	made on	12:35:00	12:40:00	
12	WT	OP 1	Breaker tripping in LC	made on . Spark observed in D2 , disconnected	13:15:00	13:55:00	
13	IOSA	FLS WOBR	LT not taking place due to pcrd overtension	tension released	10:30:00	10:45:00	