



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 08/10/2025

Shift: C

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	OLR ACTED	RESET DONE	23:00:00	23:10:00	
2	OHP	CO-26	OLR ACTED (3TIMES)	RESET DONE	01:40:00 03:00:00 03:40:00	01:50:00 03:10:00 03:50:00	
3	OHP	CO-84	OLR ACTED (3TIMES)	RESET DONE	02:00:00 03:20:00 03:30:00	02:10:00 03:30:00 03:40:00	
4	OHP	CR-3	OIL FLOW LEVEL LOW	FAULT RESET DONE THAN OK	05:30:00	05:40:00	
5	CHP	CC-51	MPD TRIP (6TIMES)FEEDING CONVEYOR	RESET DONE	03:30:00	05:00:00	
6	CHP	CC-54	OLR ACTED	RESET DONE	01:00:00	01:10:00	
7	CHP	CC-32 R-1	B/C STOPPING FREQUENTLY FOUND ZSS PROBE CABLE GOT CUT	ZSS PROBE CABLE JOINT DONE THAN OK	00:05:00	00:25:00	
8	CHP	CC-33 SCR-5	LT NOT TAKING PLACE CHECKED AND FOUND DRIVE FAULT P10 TRIP	RESET DONE (2TIMES)	00:30:00 02:30:00	01:10:00 02:50:00	
9	CHP	CC-32 R-1	LUFFING DOWN NOT WORKING CHECKE3D NO ELECTRICAL PROBLEM DUE TO JAMMING	CLEAR MATERIAL THAN OK	01:25:00	01:40:00	
10	CHP	CC-125	D/E SIDE CHUTE SENSOR ACTED	SENSOR CLEANED THAN OK	01:05:00	01:20:00	
11	CHP	CC-33 SCR-2	LT NOT TAKING PLACE MPCB-4 TRIPPED	RESET DONE THAN OK	02:50:00	03:10:00	
12	CHP	CC-40 SCR-3	B/C OLR ACTED	RESET DONE	04:10:00	04:20:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 08/10/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC-38 SCR-6	SLEW NOT WORKING OIL LEVEL LOW	INFORMED TO MECHANICAL	03:45:00	04:00:00	
14	CHP	CC-33 SCR-5	B/W OLR ACTED	RESET DONE	04:45:00	05:10:00	
15	CHP	CC-38 SCR-6	SLEW NOT WORKING RIGHT LIMIT ACTED	LIMIT RELEASE THAN OK	05:10:00	05:20:00	
16	WT	OT-1	REPORTED NOT MOVE FOUND DRIVE-1PGF1, FAULT TRIP	RESET DONE	23:30:00	23:40:00	