



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 28/07/2025

Area: WT

Equipment	Job
CC-7,8,9 Tunnel	35W LED replaced
CC-7,8,9 Tunnel	4 no's of 30W LED replaced.
CC-7,8,9 Tunnel	3 no's of 200W LED replaced.
CC-7,8,9 Tunnel	2 no's of 150W SV fittings circuit problem rectified.