



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 26/07/2025

Shift: A

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO 6A	YARD CONVEYOR ZSS interlock problem,	zss cage replaced	11:20:00	12:10:00	
2	OHP	RBF 1A	emergency push button acted	released	12:00:00	12:10:00	
3	OHP	VS1A	Over load acted	Reset done	13:00:00	13:02:00	
4	OHP	CR1	Pump 1 not working found Power MPCB tripped	Reset done	13:10:00	13:19:00	
5	OHP	TT2	Position indication not coming to CO20	Found Ok positioned properly then ok	11:30:00	11:45:00	
6	OHP	TBs on Co20	LBS not working found ZSS probe cable got cut	Rejointed then ok	09:30:00	09:45:00	
7	OHP	BRC on CO32	PB not released	Get released then ok	11:50:00	11:55:00	
8	OHP	BRCon CO31	BC not running found Bc belt folded and belt not running but motor running	Informed to operation	08:10:00	08:25:00	
9	CHP	CC 114	olr acted	reset	09:00:00	09:10:00	
10	CHP	CC 54	OLR acted	reset	09:20:00	09:25:00	
11	CHP	CC 51	ZSS acted due to belt slipping	informed operation	10:00:00	10:20:00	
12	CHP	CC 40 S1	Lt not working, OT acted	OT released	06:30:00	06:40:00	
13	CHP	CC 104 SCR9	slew not working, pump motor trips in overload	mpr reset	08:00:00	08:10:00	
14	CHP	CC 112 scr8	B/C stop due to CJS, jamming	informed operation	08:10:00	08:20:00	
15	CHP	CC 203	motor not running, mpd trips in ol	reset	10:00:00	10:10:00	
16	CHP	CC 111 R1	b/c not stop, interlock zss cage stucked	cage coal removed than ok	11:30:00	11:50:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/07/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
17	CHP	CC20	Chut sensor problem found CJB field wires tightened	chute sensor cleaned then ok	09:40:00	09:45:00	
18	CHP	SCr5 on CC32	BC not running found motor over load trip in MPD	Reset done	12:40:00	12:50:00	
19	CHP	SCR6 on CC39	Slew not working found oil levl low	Informed to mechanical	12:40:00	12:50:00	
20	CHP	CC17 belt	Over load trip	Reset done	13:53:00	13:56:00	
21	WT	OT4	Drive 2 tripped on PGF1 fault	Reset done	07:05:00 08:50:00	07:10:00 08:53:00	
22	WT	CC2 belt	Healthy stop checked found gear box not rotating	Informed to mechanical	13:20:00	13:35:00	