



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/10/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO 10A(C)	MPCB tripped	made it on	00:30:00	00:40:00	
2	OHP	WOBR on CO 25	b/c not running,zss probe damaged	probe replaced	01:45:00	02:20:00	
3	OHP	co 6A	bRS not resetting,sensor not getting power supply	in TB power is there 24 V but sensor not getting on,no spare sensor available	02:10:00	02:25:00	BRS bypassed in module,to be checked
4	OHP	WOBR on co 6A	b/c not running,mechanical gear box problem	informed operation	05:00:00	05:30:00	
5	CHP	CC 35 SCR3	no power ,LT,b/c LUff,slew not working	wrong complaint power ok,all things are working	03:35:00	03:50:00	
6	CHP	CC 12	BRS acted due to material fallen on sensor	reset ,and sensor cleaned	23:50:00	23:59:00	
7	CHP	CC 25 TT	CS acted due to rain	reset	00:30:00	00:40:00	
8	CHP	CC 29	OLR acted	reset	04:25:00	04:30:00	
9	CHP	CC 38 SCR6	LT not working,drive tripped,due to track jamming	reset	00:25:00	00:35:00	
10	WT	OT 5	no movement,D1 and d2 tripped in load slip fault	reset	04:05:00	04:12:00	
11	WT	CP 3	no movement,D3 olr acted	reset	01:10:00	01:20:00	
12	WT	CP 3	no movement,communication problem,	power recycled in LC	04:00:00	04:15:00	