



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/11/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 8	OLR ACTED	RESET	23:00:00 23:45:00	23:15:00 00:00:00	
2	OHP	VF 1A	OLR ACTED	RESET	22:20:00	22:30:00	
3	OHP	WBR ON CO 6A B/W	ACC PRESSURE ACTED	INFORMED TO MECH	22:40:00	23:00:00	
4	OHP	CO 29	OLR ACTED	RESET	03:00:00	03:05:00	
5	OHP	BRC ON CO 32	B/W 2 ZSS FAULT ACTED	RESET	04:30:00	04:50:00	
6	OHP	WBR ON CO 25	SLEW DRIVE TRIPPED	RESET	04:45:00	05:00:00	
7	OHP	WBR ON CO 26	B/W OLR ACTED	RESET	03:30:00	03:45:00	
8	CHP	CC 51	FEEDING CONVEYOR OLR ACTED	RESET	01:20:00	04:30:00	3 TIMES
9	CHP	CC 54	OLR ACTED	RESET	01:45:00	01:50:00	
10	CHP	CC 113A	OLR ACTED	RESET	22:30:00	22:50:00	
11	CHP	CC 58	ZSS PROBE CHANGED	KEPT IN CIRCUIT	23:00:00	23:45:00	
12	CHP	CC 32	OLR ACTED	RESET	22:30:00	22:40:00	
13	CHP	CC 203	OLR ACTED	RESET	23:20:00	23:30:00	
14	CHP	SCR 5 ON CC 33 LT	DRIVE TRIPPED	RESET	02:35:00	02:50:00	
15	CHP	CC 125	OLR ACTED	RESET	05:20:00	05:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/11/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	CHP	CC 112	TRIPPING DUE TO EARTH FAULT IN ONE B PHASE IN ONE	ONE CABLE REMOVED AND GIVEN CLEARANCE	02:10:00	05:45:00	
17	WT	OT5	D2 TRIPPED	RESET	05:35:00	05:45:00	
18	IOSA	OC 7B	ZSS CAGE STUCKED WITH STONE	REMOVED	04:45:00	05:05:00	