



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT 2	no power,R phase missing,old joint problem	old joint opened and properly jointed	03:15:00	04:15:00	
2	CHP	CC 24	CS acted	reset done	22:30:00	22:40:00	
3	CHP	CC 26 TT on 37	position bit missing,TT position problem	TT positioned properly	22:45:00	22:55:00	
4	CHP	CC 31 SCR4	LT not working,OT acted	OT released	01:10:00	01:20:00	
5	CHP	CC 34 SCr1	LT not working,drive tripped	reset	03:30:00	03:45:00	
6	CHP	C 51	mpd tripped 11 times	reset	23:00:00	05:30:00	
7	CHP	CC 131	olr acted 5 times	reset	22:57:00	05:50:00	
8	CHP	CC 54	olr acted	reset	01:04:00	01:09:00	
9	CHP	CC 117	olr acted	reset	01:20:00	01:25:00	
10	WT	OT 1	D1 tripped in PGF1 fault	reset done	05:20:00	05:25:00	
11	IOSA	OC 23A	conveyor stops due to zss	,zss probe adjusted	01:30:00	01:50:00	