



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 14/11/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO 25 SLEW	DRIVE TRIPPED	RESET	00:00:00	00:15:00	
2	OHP	CO 29	OLR ACTED	RESET	01:25:00	01:30:00	
3	OHP	CO 26	OLR ACTED	RESET	01:55:00 04:00:00	02:00:00 04:10:00	
4	OHP	BRC ON CO 32	HYD PUMP NOT GETTING ON DUE TO GLASS FUSE BLOWN	REPLACED THEN OK	04:30:00	05:45:00	
5	OHP	VF 1A	M1 OLR ACTED	RESET	04:05:00 05:00:00 22:40:00	04:10:00 05:10:00 22:50:00	
6	OHP	RSCO 10A ZSS ACTING	PROBE CHECK NUT LOOSE	ADJUSTMENT DONE	22:40:00	23:00:00	
7	CHP	SCR1 ON CC 34 LT	M1 TRIPPED	MADE IT ON	01:10:00	01:25:00	
8	CHP	SCR 9 ON CC 104 SLEW	MPD ACTED	RESET	02:10:00	02:25:00	
9	CHP	SCR1 ON CC 34	LUFF UP LIMIT STUCKED	RELEASED	02:35:00	02:50:00	
10	CHP	CC 125	OLR ACTED	RESET	02:30:00	02:45:00	
11	CHP	CC 28	OLR ACTED	RESET	01:00:00 01:40:00	01:10:00 01:50:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/11/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC 51	FEEDING CONV TRIPPED	RESET	00:50:00	06:00:00	8 TIMES
13	CHP	CC 117	OLR ACTED	RESERT	05:55:00	06:00:00	
14	CHP	CC 54	OLR ACTED	RESET	23:00:00	03:00:00	4 TIMES
15	WT	OT2	DRIVE 2 PGF1 ACTED	RESET	22:40:00	22:45:00	