



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/06/2025

Area: WT

Equipment	Job
MIS	Ore and Coal Tunnel Exhaust Fans,checked and kept on running
MIS	Ore side dead end lighting checked found 3 pole MCB trip,made it ON and circuit problem rectified
CT 1 and 2 series	panel and motor side ppm done
OP 1,3,8 and CP3	after rake maintenance done