



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/10/2025

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 29	OLR ACTED	RESET	14:30:00 15:30:00	14:40:00 15:40:00	
2	OHP	CO 77	OLR ACTED	RESET	15:00:00	15:10:00	
3	OHP	CO 32 BRC	ZSS INTERLOCK CAGE HIGH LOOSE CONNECTION	TIGHTENED	16:20:00	16:25:00	
4	OHP	TBS ON CO 7A	LEFT BOOM CONTROL TRIPPING DUE TO CABLE GOT CRUSHED WUTH BOOM	CABLE REJOINTED THEN OK	16:30:00	18:00:00	
5	OHP	RSCO 10A	OLR ACTED	RESET	15:15:00	15:30:00	
6	OHP	CC 114	OLR ACTED	RESET	21:40:00	21:50:00	
7	OHP	CO 10 A	OLR ACTED	RESET	15:00:00 19:00:00	15:10:00 19:10:00	
8	OHP	VF1A	M1 POWER MPCB TRIPPED	RESET	18:00:00	18:10:00	
9	OHP	OP10	BREAKER TRIPPED	MADE IT ON	20:30:00	21:00:00	
10	CHP	SCR2 ON CC 34	B/C C/S ACTED	INFORMED TO OPRN	19:45:00	20:20:00	
11	CHP	CC51	FEEDING CONVEYOR TRIPPED	RESET	15:00:00	22:00:00	10 TIMES
12	WT	OP2	D1 TRIPPED	RESET DONE	16:00:00	16:15:00	
13	WT	OP 10	BREAKER TRIPPED IN PUSHER AND COMMUNICATION PROBLEM	BREAKER MADE ON AND POE POWER RECYCLED COMMUNICATION ESTABLISHED	14:00:00	16:00:00	