



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/06/2025

Incharge(s): V Balaji Naik

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO8	ZSScage struck in reverse and probe damage	Probe replaces and cage placed properly	02:20:00	03:15:00	Return roller not available fallen from conveyor frame is to be fixed by mech dept informed to mech dept 02.20 pm to 03.15