



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/11/2025

Incharge(s): Nagendra Midde

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|------------------|--|---|----------|----------|---------|
| 1 | OHP | BRC ON CO 33M LT | EMERGENCY STOP ACTED | RELEASED | 16:50:00 | 17:05:00 | |
| 2 | OHP | BRC ON CO 8A | B/W 2 RUNNING WITH OUT LOAD BUT ZSS ACTING WHILE RUNNING ON LOAD | INFORMED TO MECH | 21:15:00 | 21:30:00 | |
| 3 | OHP | VF 21 | OLR ACTED | RESET | 18:45:00 | 18:55:00 | |
| 4 | OHP | CO 30 | c/s not acting, | SENSITIVITY ADJUSTED AS PER INSTRUMENTATION INSTRUCTION | 21:30:00 | 21:50:00 | |
| 5 | CHP | CC 51 | OLR ACTED | RESET | 16:00:00 | 20:45:00 | 3 TIMES |
| 6 | CHP | CC 51 | FEEDING CONV OLR ACTED | RESET | 17:55:00 | 21:20:00 | 4 TIMES |
| 7 | CHP | R1 ON CC 32 | LUFF OIL LEAKAGE | INFORMED TO MECH | 17:00:00 | 17:20:00 | |
| 8 | WT | OT1 | DRIVE 1 TRIPPED ON PGF1 FAULT | RESET | 15:20:00 | 15:30:00 | |