



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/05/2025

Shift: A

Incharge(s): Lal Singh

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|--|--|----------------------------------|----------------------------------|-------------------|
| 1 | OHP | CO-35 | TRIPPED ON OLR | RESET DONE | 07:35:00 10:15:00 13:00:00 | 07:45:00 10:20:00 13:10:00 | |
| 2 | OHP | CO-29 | TRIPPED ON OLR | RESET DONE | 08:40:00 | 08:50:00 | |
| 3 | OHP | CO-26 | TRIPPED ON OLR | RESET DONE | 08:50:00 | 09:00:00 | |
| 4 | OHP | CC-32 SCR-5 | BC STOPPING FREQUENTLY | PLC POWER RECYCLED | 12:30:00 | 13:00:00 | |
| 5 | CHP | CC-36 SCR-1 | LT END LIMIT BYPASS REQ FROM OPERATION | BYPASSED | 07:20:00 | 08:00:00 | AGAIN KEPT IN CKT |
| 6 | CHP | CC-107 | TRIPPED IN OLR | RESET DONE | 09:27:00 12:15:00 | 09:30:00 12:20:00 | |
| 7 | CHP | CC-54 | TRIPPED ON OLR | RESET DONE | 08:00:00 | 08:05:00 | |
| 8 | CHP | CC-131 | TRIPPED IN OVER LOAD | RESET DONE | 07:10:00 | 07:15:00 | |
| 9 | CHP | CC-33 | BRS BYPASS REQ | BYPASSED IN SYSTEM | 13:00:00 | 13:05:00 | |
| 10 | CHP | CC-107 | BRS FREQUENTLY ACTING IN EMPTY BELT ALSO | BYPASSED IN SYSTEM | 10:30:00 | 10:45:00 | TO BE CHECKED |
| 11 | WT | OP-8 | DRIVE 2 TRIPPING CONTINUOUSLY | D2 POWER MADE OFF AND HEALTHY AND FEEDBACK BYPASSED AND TESTED | 08:40:00 | 09:00:00 | |
| 12 | WT | SCO-1A | STOPPING ON ZSS FAULT | MODULE POWER SUPPLY PROBLEM BYPASSED | 13:20:00 | 13:30:00 | TO BE CHECKED |