



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 10/10/2025

Area: CHP

Equipment	Job
STK-3	Lower E-House roof sheet welding job is under progress
STK-3	Slew movement, motors given power from drive without coupling and tested. One motor mounted on base coupling fixed and tested the movement with drive. Found ok
CC-43,46,49,126,125	Running inspection done
CC-40,42,46	ppm done