



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 08/09/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO-6A	BC DIRECTION CHANG REQUEST FROM OPR FOR CLEANING	DIRECTION CHANGED ... NORMALIZED AFTER CLEANING	19:00:00	19:30:00	
2	OHP	CO-35	TRIPPED ON OLR	RESET DONE	20:20:00	20:30:00	
3	OHP	CO-18	TRIPPED ON OLR	RESET DONE	20:25:00	20:30:00	
4	OHP	CO-25	OLR ACTED	RESET DONE	19:05:00 19:45:00	19:20:00 20:00:00	
5	CHP	CC-51	MPD TRIPPED (3 TIMES )	RESET DONE	15:00:00	18:15:00	
6	CHP	CC-40 SCR-3	LT NOT WORKING	PCRD OVER TENSION ACTED .. RELEASED	19:00:00	19:10:00	
7	WT	CO-4	TRIPPED ON OLR	RESET DONE	20:00:00	20:05:00	
8	WT	OT -5	LS-4 STUCK	MADE FREE	18:00:00	18:15:00	