



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 27/07/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-7	P/C in bypass	checked and kept in line	16:00:00	17:00:00	
2	OHP	WOBR-4 on CO-6A	Reported Slew tripping on charge pressure fault	Checked and found electrical side okay. On command Charge pressure found to be dropping	15:50:00	17:30:00	Informed to operation and mechanical
3	CHP	CC-23	Reported ZSS acting	ZSS acted due to material overload. Material cleared and tested okay.	19:00:00	19:15:00	informed to operation
4	CHP	CC-23	Reported Chute sensor acted	chute sensor acted due to wet material. Reset done	19:30:00	19:40:00	informed to operation
5	CHP	CC-38 SCR-3	Reported B/C stopping	Signal missing. LT forward done and antenna cleaning done and tested okay	16:12:00	16:25:00	
6	CHP	CC-36 S-2	Reported LT not taking place	M2 and M4 OLR acted. Reset done	19:43:00	19:56:00	
7	CHP	CC-33 SCR-4	Reported B/w and slew not moving	Checked and found both to be working fine.	19:46:00	19:56:00	Wrong complaint
8	CHP	CC-44	Reported not healthy	OLR acted. Reset done.	21:37:00	21:40:00	
9	CHP	CC-132	Reported ZSS acted	Tailend jamming found.	17:00:00	17:30:00	Informed to operation
10	CHP	CC-114	Reported not healthy	OLR acted. reset done	21:45:00	21:50:00	
11	WT	CO-4	Reported not healthy	OLR acted. Reset done	14:20:00	14:25:00	