



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 26/10/2025

Incharge(s): Lal Singh

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------------|--|---|----------------------|----------------------|---------|
| 1 | OHP | WBOR ON CO-6A | BC NOT RUNNING ... BS ACTED DUE TO OFF CENTERING | RESET | 16:10:00 | 16:25:00 | |
| 2 | OHP | CO-58 | MPCB TRIPPED | MADE ON | 18:10:00 | 18:20:00 | |
| 3 | OHP | TBS ON CO-7A | ACB TRIPPED AND BC NOT RUNNING | ACB MADE ON ... BC JAMMING ... INFORMED OPERATION | 20:00:00 | 20:15:00 | |
| 4 | OHP | TT-2 AND TT-3ON CO-22 | SENSOR PROBLEM | BYPASSED | 19:00:00 | 19:15:00 | |
| 5 | CHP | CC-51 | MPD TRIP 20 TIMES | RESET DONE | 14:30:00 | 21:30:00 | |
| 6 | CHP | CC-51 | TRIPPED ON OLR | RESET DONE | 14:40:00 16:50:00 | 14:45:00 16:55:00 | |
| 7 | CHP | CC 37 SCR-7 | MOTORS TRIPPED DUE TO TRACK JAMMING | RESET AND INFORMED FOR CLEANING | 19:15:00 | 19:25:00 | |
| 8 | CHP | CC-112 SCR-8 | BC TRIPPED ON OLR | RESET DONE | 20:37:00 | 20:45:00 | |
| 9 | CHP | CC-35 SCR-3 | LT NOT WORKING MOTOR TRIPPED | RESET DONE | 21:30:00 | 21:40:00 | |
| 10 | CHP | CC-54 | TRIPPED 14 TIMES | RESET DONE | 15:30:00 | 21:45:00 | |
| 11 | WT | AF-2A | DRIVE TRIPPED | RESET DONE | 21:20:00 | 21:25:00 | |