



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 24/12/2025

Area: CHP

Equipment	Job
CC 50 D/E	One 120W LED fixture replaced
SCR 6	6 nos 30W bulbs replaced and improved lighting
SCR 1	LUFF UP and DOWN limits replaced and tested
CC 47,48,126,220,221	Motor greasing was done
CC 25,29,44,102	PPM was done
RG EOT Crane	PPM was done
LC 2	Rooms cleaning under progress