



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 13/02/2026

Area: IOSA

Equipment	Job
THRUSTER BRAKE	BEARINGS REPLACED FOR THRUSTER BRAKE UNIT AND COIL (ERS REPAIRED) FIXED , OPERATION CHECKED AND CURRENT RECORDED.
BLENDER RECLAIMER	MPCB REPLACED AND TRIAL TAKEN FOR LT MOTOR M5 AND M7.
ZSS UNITS	INSPECTION , MAINTENANCE AND FEEDBACK CHECKED FOR OC-3A,4A ,5A,6A,7A AND 7B CONVEYORS
BRS UNITS	INSPECTION, MAINTENANCE AND FEEDBACK DONE ON MODULE AND SENSORS OF BRS AT OC- 4A,5A,6A,7A,7B CONVEYORS
OC-7C	PPM DONE ON MOTOR SIDE.