



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 20/08/2025

Area: OHP

Equipment	Job
tis on cc-7,8,9	inspection is done and found electrical side no issues, informed mechanical to rectify, left in bypass mode.
tt wireless	old panels shifted to 1-141lc3
co-8.9.2a	brs inspection is done.
co-2a	local start pb replaced ; cjb drawing is made ready and provided at cjb.
co-5	motor and panel side ppm is done
spare motor for vf-1a/2a	bearings and collar fixing is done.
co-11a,12a,13a,14a,42a,49	belt weigh bridges ppm is done
bf-1a,2a	chute vibrators ppm is done
TBS	LT new motors couplings received from ARS
om-12	de-watering is done
tbs on co-22	rbc zss probe replaced
brc-1 on co-28	ppm is done ; brakes adjustment is done.