



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 26/11/2025

Area: IOSA

| Equipment         | Job  |
|-------------------|--|
| OJH-4B            | PPM DONE ON ELECTRICAL HOIST AT OC-7C TAILEND.   |
| BLENDER RECLAIMER | BRIDGE CONVEYOR PULLCHORD BASE GOT DAMAGED. REPLACED THE SWITCH AND TRIAL RUN TAKEN.         |
| OC-13A            | PULL CHORD HARDWARE SIGNAL NOT COMING. CHECKED AND RECTIFIED AND SAME AND REMOVED BYPASS.    |
| WOBR-LnT          | MAINTENANCE DONE ON SLIPRING ASSEMBLY , TRANSFORMER HT AND LT SIDE TERMINATION.              |
| OC-36A            | LIGHTING DEFECTS RECTIFICATION IS IN PROGRESS. ONE LIGHT FITTING PROVIDED NEW HEAD END AREA. |