



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/06/2025

Shift: B

Incharge(s): G Eswara Rao

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------|--|------------------------------------|----------------------|----------------------|------------------------------------|
| 1 | OHP | brc on co 34 | bw 1 zss acting/ | zss module replaced then tested ok | 16:20:00 | 16:45:00 | |
| 2 | OHP | co 45 | reported red/mpcb tripped | checked and found motor got burnt/ | 19:30:00 | 20:00:00 | motor replacement work is going on |
| 3 | OHP | rsco 10a | b/d tripped on olr | reset done | 17:15:00 | 17:25:00 | |
| 4 | OHP | tt 1 on co 21 | chute position sensor got damaged | bypass done | 21:00:00 | 21:10:00 | |
| 5 | OHP | tbs on co 22 | chute vibrator motor not working/olr acted | reset done | 15:35:00 | 16:00:00 | |
| 6 | OHP | co 84 | tripped on olr 4 times | reset done | 17:10:00 | 18:15:00 | |
| 7 | OHP | co 84 | belt scale bypass removed | for operation request | 19:30:00 | 19:35:00 | |
| 8 | OHP | brc on co 30 | ct not working/chain fallen | informed to operation | 21:20:00 | 21:45:00 | |
| 9 | OHP | brc on co 34 | bw 1 zss acting/ | zss bypassed at module | 21:00:00 | 21:15:00 | |
| 10 | CHP | cc 131 | tripped on olr 2 times | reset done | 17:05:00 17:30:00 | 17:10:00 17:35:00 | |
| 11 | CHP | cc117 | tripped on olr | reset done | 20:10:00 | 20:30:00 | |
| 12 | CHP | cc 51 | tripped on olr | reset done | 15:50:00 | 16:00:00 | |
| 13 | CHP | cc 51 | belt sway acted due to off centring | inform to ope. and mech | 19:50:00 | 20:00:00 | |
| 14 | CHP | cc 114 | brs bypassed at i/o rack | for operation requirement | 19:50:00 | 20:00:00 | |
| 15 | CHP | scr 10 on cc105 | yard conv. interlock zss cage problem | cage replaced then ok | 14:15:00 | 14:50:00 | |



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/06/2025

Incharge(s): G Eswara Rao

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--|------------------|----------|----------|---------|
| 16 | CHP | cc 105.,cc104 | bss acted/qac 5 mcb tripped at plc panel | mcb made on | 17:00:00 | 17:15:00 | |
| 17 | CHP | cc111 | brs acted | reset done | 17:55:00 | 18:05:00 | |
| 18 | CHP | scr 6 on cc40 | It not taking place/pcrd tension acted | tension released | 18:30:00 | 18:40:00 | |