



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 25/09/2025

Shift: C

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment              | Problem                       | Action   | From     | To       | Remarks   |
|-------|------|------------------------|-------------------------------|--|----------|----------|---|
| 1     | OHP  | CO 15                  | OLR ACTED                     | RESET  | 04:00:00 | 04:05:00 |   |
| 2     | OHP  | BRC ON CO 32           | OLR ACTED C/S BYPASSED        | RESET  | 02:00:00 | 02:10:00 | C/S ACTING FREQUENTLY PROBE LENGTH HAS TO BE ADJUSTED |
| 3     | OHP  | CO 29                  | OLR ACTED                     | RESET  | 23:50:00 | 00:00:00 |   |
| 4     | OHP  | BRC ON CO 32           | O/T ACTED DUE TO CABLE ZIGZAG | RELEASED AND INFORMED MECH TO GUIDE ADJUSTMENT | 05:40:00 | 06:00:00 |   |
| 5     | OHP  | VS 1A                  | OLR ACTED                     | RESET  | 03:40:00 | 03:50:00 |   |
| 6     | OHP  | RSCO 6A CARRIAGE DRIVE | OLR ACTED                     | RESET  | 01:40:00 | 01:55:00 |   |
| 7     | OHP  | CO 10A                 | OLR ACTED                     | RESET  | 04:50:00 | 05:00:00 |   |
| 8     | OHP  | CO 49                  | OLR ACTED                     | RESET  | 05:20:00 | 05:30:00 |   |
| 9     | CHP  | scr7 ON CC 37          | LT O/T ACTED                  | RELEASED                                       | 23:05:00 | 23:25:00 |   |
| 10    | CHP  | SCR 4 ON CC 31         | CHARGE PRESSURE ACTED         | RESET  | 01:35:00 | 01:55:00 |   |
| 11    | CHP  | SCR 2 ON CC 34         | LT O/T ACTED                  | RELEASED                                       | 23:55:00 | 00:15:00 |   |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/09/2025

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment             | Problem                  | Action           | From                 | To                   | Remarks                                      |
|-------|------|-----------------------|--------------------------|------------------|----------------------|----------------------|--|
| 12    | CHP  | SCR 3 ON<br>CC 40 B/C | OLR ACTED                | RESET            | 01:45:00             | 02:00:00             |  |
| 13    | CHP  | R1 ON CC<br>33        | SLEW DRIVE TRIPPED       | RESET            | 04:45:00             | 05:00:00             |  |
| 14    | CHP  | CC 202                | BSS ACTED                | BY PASSED        | 04:20:00             | 05:00:00             | C/S<br>BYPASS<br>LOOP<br>LOOSE TIG<br>HTENED |
| 15    | CHP  | SCR 1 ON<br>CC 36     | LUFF OIL LEAKAGE         | INFORMED TO MECH | 05:20:00             | 05:40:00             |  |
| 16    | CHP  | CC 58 T/T<br>POSITION | SENSOR BYPASS LOOP LOOSE | TIGHTENED        | 02:30:00             | 02:45:00             |  |
| 17    | CHP  | CC51                  | FEEDING CONV OLR ACTED   | RESET            | 23:30:00             | 06:00:00             | 7 TIMES                                      |
| 18    | CHP  | CC 31 F/G             | OLR ACTED                | RESET            | 01:00:00<br>23:00:00 | 01:10:00<br>23:10:00 |  |
| 19    | CHP  | CC 28                 | OLR ACTED                | RESET            | 04:50:00             | 05:00:00             |  |
| 20    | WT   | OT2                   | D2 DRIVE TRIPPED ON PGF1 | RESET            | 03:40:00             | 03:45:00             |  |