



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 14/01/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 30 B/W 2	MOTOR WINDING CABLE INSULATION GOT RUB AND DUE TO TB COVER LOOSE AND MCCB TRIPPING	TB REMOVED, WINDING CABLE PROPERLY INSULATED POWER CABLE CONNECTED DIRECTLY .	01:30:00	03:30:00	
2	OHP	CO 26	OLR ACTED	RESET	00:00:00 01:25:00	00:10:00 01:30:00	
3	OHP	BRC ON CO 33 M B/C	OLR ACTED DUE TO JAMMING	RESET	00:20:00	00:40:00	
4	OHP	BRC ON CO 33M LT	PCRD O/T ACTED	RESET	03:10:00	03:25:00	
5	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	22:30:00	05:45:00	18 TIMES
6	WT	OP2 and OP 4 NOT MOVING	COMMUNICATION PROBLEM	MODEM CHANGED BUT STILL NOT COMING	05:30:00	06:00:00	CHECKING UNDER PROGRESS