



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/11/2025

Area: IOSA

Equipment	Job
WOBR-FLS	TWO 110V SOURCES REMOVED FROM TB AND GIVEN DIRECTLY THROUGH MCB
BATTERY CHARGER	CHECKED AND IDENTIFIED SOURCE AND OUTGOING FOR ISOLATION.
GROUND ISOLATOR-3	MAINTENANCE DONE ON OUTGOING PANELS OF GROUND ISOLATOR-3. CLOSING,TRIPPING AND EARTH CHECKED.
YARD MACHINES	HOUSE KEEPING DONE FOR ELECTRICAL HOUSE OF TBS, BRC AND WOBR-LnT
MISC	CHUTE VIBRATOR MOTORS MEGGERED AND TRIAL RUN TAKEN. VIBRATION ADJUSTED.
TBS	PCRD CHAIN GUIDE TENSIONING UNIT BROKEN. RESTORED AFTER RECTIFICATION
OC-16A , OC-17A	PPM DONE ON MOTOR SIDE.