



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 13/06/2025

Area: WT

Equipment	Job
OT 4	200 W LED fitting replaced at out haul side
CP 1 to 4	communication problem ,LAN cable replaced 26 mtrs
OP 3	panel and motor side ppm done
OP 3,5 and 8	after rake maintenance done