



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 01/02/2026

Incharge(s): Nagendra Midde

Shift: A

| Sl No | Area | Equipment | Problem                | Action | From                 | To                   | Remarks |
|-------|------|-----------|------------------------|--------|----------------------|----------------------|---------|
| 1     | OHP  | RSCO 1A   | CD MPCB TRIPPED        | RESET  | 10:50:00             | 11:00:00             |         |
| 2     | OHP  | CO 16     | OLR ACTED              | RESET  | 13:00:00<br>13:30:00 | 13:10:00<br>13:40:00 |         |
| 3     | CHP  | CC 28     | OLR ACTED              | RESET  | 07:20:00<br>08:00:00 | 07:25:00<br>08:05:00 |         |
| 4     | CHP  | CC 29     | OLR ACTED              | RESET  | 12:30:00             | 12:35:00             |         |
| 5     | CHP  | CC 51     | FEEDING CONV MPD ACTED | RESET  | 06:50:00             | 08:20:00             | 5 TIMES |
| 6     | CHP  | CC 54     | OLR ACTED              | RESET  | 07:30:00             | 08:25:00             | 6 TIMES |
| 7     | CHP  | CC 58     | OLR ACTED              | RESET  | 09:40:00             | 09:55:00             |         |
| 8     | WT   | CO 3      | OLR ACTED              | RESET  | 11:10:00             | 11:15:00             |         |