



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 24/10/2025

Incharge(s): Nagendra Midde

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-------------------|-----------------------------------|---------------------------|--|--|---------|
| 1 | OHP | CO 29 | OLR ACTED | RESET | 07:30:00 08:30:00 08:55:00 12:00:00 | 07:40:00 08:40:00 09:00:00 12:10:00 | |
| 2 | OHP | CO 26 | OLR ACTED | RESET | 07:40:00 08:15:00 | 07:50:00 08:25:00 | |
| 3 | OHP | BRC ON CO 34 | LT O/T ACTED DUE TO GUIDE PROBLEM | RELEASED INFORMED TO MECH | 08:30:00 | 08:40:00 | |
| 4 | OHP | BRC ON CO 31 | B/C OLR ACTED | RESET | 09:40:00 10:50:00 | 09:55:00 11:00:00 | |
| 5 | OHP | WBR ON CO 26 | SLEW DRIVE TRIPPED | RESET | 10:40:00 | 10:50:00 | |
| 6 | CHP | SCR 6 ON CC38 | LT DRIVE TRIPPED | RESET | 12:15:00 12:55:00 | 12:25:00 13:00:00 | |
| 7 | CHP | CC 31 | OLR ACTED | RESET | 12:30:00 | 12:35:00 | |
| 8 | CHP | SCR 3 ON CC 35 | B/C OLR ACTED | RESET | 13:20:00 | 13:30:00 | |
| 9 | CHP | CC 29 | F/G OLR ACTED | RESET | 06:30:00 07:50:00 | 06:35:00 08:00:00 | |
| 10 | CHP | CC 117 | OLR ACTED | RESET | 10:40:00 | 10:50:00 | |
| 11 | CHP | CC 51 | FEEDING MPD TRIPPED | RESET | 13:15:00 | 13:25:00 | |
| 12 | CHP | CC 51 | OLR ACTED | RESET | 12:45:00 | 12:50:00 | |
| 13 | CHP | CC 54 | OLR ACTED | RESET | 13:20:00 | 13:25:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/10/2025

Incharge(s): Nagendra Midde

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|-----------------------------------|--------|----------------------|----------------------|--|
| 14 | WT | AF4 | DRIVE TRIPPED DUE TO GROUND FAULT | RESET | 12:00:00 12:20:00 | 12:05:00 13:00:00 | MOTOR ME GGERED E VERYTHIN G OK |