



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/05/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 3B	BRS bypass request	Bypassed in module	05:30:00	05:35:00	
2	OHP	CO 29	OLR acted	reset done	01:50:00	02:00:00	
3	OHP	TBS on CO 22	LT not working due to PCRD overtension	Overtension released	02:10:00	02:30:00	
4	OHP	CO 21	OLR acted	reset done	01:50:00	02:00:00	
5	OHP	CO 34	OLR acted	reset done	02:50:00	03:00:00	
6	OHP	BRC on CO 33M	BC not running	Cabin side emergency acted , released	03:45:00	04:00:00	
7	CHP	CC 26 Flap gate	MPCB tripped	reset done	23:50:00	00:00:00	
8	CHP	CC 125	Tripped in overload	reset done	22:00:00	22:05:00	6.30 to 6.35 pm (B shift)
9	CHP	CC 104 , SCR 9	BC not running	Discharge chute jamming , informed to operation for cleaning	22:00:00	22:05:00	9.35 to 9.40 pm (B shift)
10	CHP	CC 39 , SCR 7	LT not working	PCRD overtension released	00:40:00	01:00:00	
11	CHP	CC 39 , SCR 7	LT not working . Also slewing not working	LT drive reset done. Slew limit switch acted , released	02:30:00	03:00:00	
12	CHP	CC 104 , SCR 9	Slewing not working	Limit acted due to jamming , informed to operation	03:55:00	04:10:00	
13	CHP	CC 111, S 3	LT not working	Drive reset	04:38:00	04:58:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/05/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 36 , SCR 1	BC not working due to chute jamming	Sensor cleaned and informed to operation	05:20:00	05:30:00	
15	CHP	CC 201	OLR acted	reset done	04:15:00	04:20:00	
16	CHP	CC 117	OLR acted	reset done	22:00:00	22:05:00	9.00 pm to 9.15 pm (B shift)
17	CHP	CC 131	OLR acted (5 times)	reset done	22:00:00	01:45:00	
18	CHP	CC 54	OLR acted (10 times)	reset done	23:35:00	02:15:00	
19	WT	CP 2 and CP 4	Communication problem	PLC power recycled at LC 10A	04:15:00	04:25:00	