



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 29/05/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO21	RIGHT LUFF NOT TAKING PLACE OLR ACTED	RESET	06:30:00	06:45:00	BRAKE ADJUSTED
2	OHP	CO 29	OLR ACTED	RESET	08:45:00	08:55:00	
3	OHP	CO 35	OLR ACTED	RESET	09:00:00	09:15:00	
4	OHP	CO 34	OLR ACTED	RESET	10:30:00	10:40:00	
5	OHP	BRC ON CO33M	B/W 2 OLR ACTED	RESET DONE	10:40:00	11:00:00	
6	OHP	TT2 ON CO19	POSITION INDICATION PROBLEM CABLE GOT CUT	JOINT DONE THAN OK	10:40:00	11:00:00	
7	CHP	CC131	OLR ACTED ( 2 times)	RESET	07:10:00	07:30:00	DUE TO MATERIAL JAMMING
8	CHP	CC 32	OLR TRIPPED	RESET	07:55:00	08:00:00	
9	CHP	SCR 9 ON CC104	B/C NOT RUNNING	FAULT RESET DONE THAN OK	09:50:00	10:00:00	
10	CHP	SCR 8 ON CC 112	LUFFING DOWN LIMIT ACTED	BY PASSED OPERATION REQUIREMENT	11:50:00	11:55:00	