



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 09/08/2025

Incharge(s): Amit Roy

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|--------------------------------------------------------------------------------|------------------------------------------------------------------------|----------------------------------------------|----------------------------------------------|-----------------------|
| 1 | OHP | RSCO-10A(C/D) | Reported not moving | OLR acted.Reset done | 23:10:00 | 23:15:00 | |
| 2 | OHP | CO-11(B/D) | Reported not healthy | MPCB tripped.Reset done | 23:50:00 | 00:00:00 | |
| 3 | OHP | CO-11(C/D) | Reported not moving | MPCB tripped.Reset done | 04:45:00 | 04:50:00 | |
| 4 | CHP | CC-54 | Reported not healthy | OLR acted. Reset done(4times) | 02:50:00 04:10:00 04:30:00 04:45:00 | 02:55:00 04:15:00 04:35:00 04:50:00 | |
| 5 | CHP | CC105 SCR-7 | Reported LT not taking place | M2 and M6 MPCB Tripped due to track jamming.Reset done | 03:28:00 | 03:40:00 | Informed to operation |
| 6 | CHP | CC104 SCR-9 | Pending from B shift.Slew and B/W not moving due to oil temperature high alarm | Air cooler and pump made on. Oil temperature came down and tested okay | 22:00:00 | 22:36:00 | |
| 7 | CHP | CC-35 SCR-1 | Reported LT not taking place | M-7 tripped due to track jamming.Reset done | 05:38:00 | 05:48:00 | Informed to operation |
| 8 | WT | OP-6 | Reported no movement | Emergency acted.Reset done | 05:00:00 | 05:10:00 | |
| 9 | WT | OC-1A | Reported ZSS acting | Checked and found material jamming | 05:20:00 | 05:30:00 | Informed to operation |