



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 30/08/2025

Area: WT

Equipment	Job
OP 9	panel and motor side ppm done
MIs	RMD room near E-Goomty,supply problem, found R-phase cable fault and changed to B-phase
OP 10	LOTUS modem checked, found fixing position changed,fixed it properly ,now OK
Mis	Key made ready and coupling fixed to OP1 ,D4 motor
OP 4 and 5	After rake maintenance done