



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/12/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|----------------------------------|--------------------|----------|----------|------------------------------|
| 1 | OHP | brc on co 32 | LT not working,OT acted | reset | 00:45:00 | 01:00:00 | |
| 2 | OHP | CO 77 | olr acted | reset | 00:50:00 | 01:00:00 | |
| 3 | OHP | BRC on Co 8A | b/w 2 not running,stone stucked | informed operation | 04:15:00 | 04:25:00 | |
| 4 | CHP | CC 38 SCR6 | b/c not running,mpd tripped | reset | 00:50:00 | 05:15:00 | full jamming,3 times tripped |
| 5 | CHP | CC 31 SCR4 | slew not working,wrong complaint | informed operation | 04:00:00 | 04:10:00 | |
| 6 | CHP | CC 32 SCR 5 | Lt not working,m6 mpcb tripped | made it on | 04:10:00 | 04:20:00 | |
| 7 | CHP | CC 105 scr 10 | b/c not running,mpd tripped | rset | 04:40:00 | 04:55:00 | |
| 8 | CHP | CC 104 SCR9 | luffing not working,mpcb tripped | made it on | 05:05:00 | 05:20:00 | |
| 9 | CHP | cc 51 | mpd tripped | reset | 04:00:00 | 04:05:00 | |
| 10 | CHP | cc 55 | olr acted | reset | 05:00:00 | 05:05:00 | |