



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/07/2025

Shift: B

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	1-14 LC7 and 1-14 LC 8	PANEL NO. 29 FEEDER 2 CLEARANCE GIVEN FROM DNW	H.T BREAKER MADE ON AT 1-12 LBDS 4 and 5	16:00:00	16:12:00	
2	OHP	co 29	tripped on olr	reset done	18:45:00	18:55:00	
3	OHP	co 35	tripped on olr	reset done	18:40:00	18:50:00	
4	OHP	tt 4 on bypass 2	chute position signal not getting to ocr	temporary bypassed	19:45:00	20:15:00	
5	OHP	co29	reported red /glass fuse blown at cjb due to earth fault in pullcard	field wires removed and kept bypass at cjb	21:10:00	21:25:00	to be kept in ckt
6	OHP	co 29	operation request brs bypass	bypass done	17:15:00	17:30:00	
7	CHP	scr 2 on cc34	slew not taking place/wrong complaint	tested ok	16:40:00	16:50:00	
8	CHP	R1 ON CC31	bc signal missing/	plc recycled then ok	18:35:00	18:50:00	now working on zss inter lock
9	CHP	cc 117	tripped on olr	reset done	15:20:00 20:15:00	15:35:00 20:30:00	
10	CHP	cc 54	tripped on olr 2 times	reset done	17:35:00 18:10:00	17:40:00 18:15:00	
11	CHP	vs 3	tripped on olr 2 times	reset done	21:05:00	21:10:00	
12	CHP	cc 40	brs acting frequently due to offcentring	inform to operation	16:10:00	16:20:00	
13	CHP	scr 5 on cc32	It not taking place/vfd drive fault on ovr	reset done	17:05:00	17:15:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/07/2025

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	cc 2 C/D	tripped on olr	reset done	16:30:00	16:40:00	